



No. 7(1)/EE/E/BSNL/ED/SNR/2021-22/68

Dated : 28.12.2021

Notice Inviting Quotation

On the behalf of C.M.D. Bharat Sanchar Nigam Limited (A Govt. Of India Enterprise), The Executive Engineer (E), BSNL Electrical Division, CTTC Complex (1st Floor), Sunder Nagar (HP) pin 175002 invites the sealed quotation for following work. The quotations must reach on 03.01.2022 up 15.00 Hrs. at this office & will be opened on the same day at 15.30 Hrs. The nature of job and quantum of work has been explained in the schedule given below. The quotations can be downloaded from www.hp.bsnl.co.in

NAME OF WORK:- Repairing of 30KVA DEA set at TE Building AUT under SSA Mandi.

S. No.	Description of items	Qty	Rate	Unit	Amount
Sub Head-1 :- Material Cost Part "A"					
1	Replacement of following damaged parts of the existing 30KVA DG set (Engine Make-Greaves, Model-4YDA MK-II) complete all as required.				
	a) Cylinder Head	1	No.	Each	
	b) Cylinder Liner	1	No.	Each	
	c) Piston Assembly Complete	1	No.	Each	
	d) Piston Ring(s) set	1	No.	Each	
	e) Set of Rubber "O" ring's Set (for 1 Cylinder Head)	1	Set	Set	
	f) Head Gasket	1	No.	Each	
	g) Lube oil	2	Liters	Liter	
2	Replacement of following rating Side handle operated Change Over Switches with sheet steel enclosure on wall / stand / in existing panel i/c interconnections, testing etc. complete as required at site.				
	a) 4 Pole, 63A, 415V with Enclosure.	1	No.	Each	
SUB TOTAL of Material Cost Part "A"					
Sub Head-2 :- Labour Cost "Part B"					
1	Labour charges of Repairing of above engine of Greaves make model-4YDA MK-II i/c transportation, dismantling, replacement of existing faulty parts, cylinder head reconditioning, testing on load complete as required.	1	Job	Job	
SUB TOTAL of Labour Cost "Part B"					
Total of Sub Head-I&II					
TOTAL IN WORDS : -					

Eligibility Conditions : -

► BSNL enlisted contractor in Electrical category IV (E) and above.

OR

► The manufacturer / authorized dealer / authorized service dealer / OEM of any of the makes of BSNL approved EA sets (Ashok Leyland / Cummins / Caterpillar / KOEL / Volvo Penta / Mahindra & Mahindra (up to 200 KVA) / Escorts (up to 30 KVA) / Eicher (up to 35 KVA)). The letter of authorization from manufacturer in original / photocopy attested by BSNL Executive will be submitted.

OR

► Experience of having successfully completed similar works in BSNL during last 7 years ending last day of month previous to the one in which applications are invited.

Followings self certified copies of Documents to be submitted along with quotation:

1. Documentary proof of satisfying the eligibility conditions as above.
2. Valid GST Registration as per GST Law (SGST/CGST/IGST as applicable).
3. Pan Number (Permanent Account Number).

Specification

1. The work shall be done as per the specification of department.
2. Time allowed for completion of work shall be 07 Days from the date of issue of work order.
3. The rates offered by the firm shall be inclusive of the GST as applicable. The firm shall claim GST with the bill clearly furnishing the complete details of GST so included. BSNL, under no circumstances, will consider any claim of GST not included in the bill. It will be the firm's responsibility to settle GST with GST authorities.
4. The agency will provide the workers with necessary Tools & Plant, Testing and safety equipments.
5. The work shall be supervised by the qualified Engineer-in-charge or his duly authorized Representative, at the site of work.
6. The layout of the work will be given by the Engineer-in-charge or his duly authorized representative at the site of work.
7. Any damage done to the building by the contractor during the execution of work shall be made good by the contractor at his risk and cost, if the damage are not made good by the contractor in reasonable time determine by the Engineer-in-charge the same will be got done at his cost departmentally after serving notice to him.
8. No extra payment will be made for any kind of transportation.
9. The spare parts used should be from the genuine spare parts manufacturers. Documantry proof of same shall be submitted.
10. The mobile oil of the DEA set shall be changed as per manufacturer's recommendation.
11. The firm shall clean the DEA set after repairs.
12. The firm shall top up the battery electrolyte without any extra cost. Check & correct cooling water level & lube oil level if required.
13. The firm shall check state of batteries, terminals for cleanliness & level of water with out the extra cost.

NOTE:- The replacement of material shall be with the same rating and make as tha the original.

(----- Sd ----)
Executive Engineer (Electrical)
BSNL Electrical Division
CTTC Complex Sundernagar.

From : -

M/s.....

Contractor Signature with Seal