

BHARAT SANCHAR NIGAM LIMITED**भारत संचार निगम लिमिटेड**

(A Govt. of India Enterprise)

(भारत सरकार का उपक्रम)

O/o Executive Engineer (E), Electrical Division, 1st Floor Block No. 35 Kasumpati Shimla-171009

कार्यालय आधिशाषी अभियंता (विदुत) भारत संचार निगम लिमिटेड ब्लॉक न. ३५ शिमला

No:-69/EE/E/BSNL/ED./SML/16-17/09

Dated:- 06-04-2016

QUOTATION

To

1. M/s R.R. Electrical Co. Vill & PO Kotkawala ,Teh. & Distt Kangra (HP).
2. M/s Hydraulic Engineering Co. Hospital Road Solan.
3. M/s. G.S. Electrical Works Vill & P.O. Amb, Distt., Una (HP).
4. M/s MERCO,Air-conditioning & Refrigeration Engineers,52-C,R-Block,Dilshad Garden,Delhi-95.
5. M/s Goel Electric Works, 80-P, Road, Ferozepur
6. M/s. Perfect Engineers,7-Doaba Market,Opp-Bus Stand,17,Parkash Nagar,Jalandhar-03
7. M/s. Sharma Electrical Co,House No-199,Ward No.6,Hamirpur(H.P).
- 8 M/s Gopal Krishan Contractor,.1310, Sector -50B, progressive Society , Chandigarh.
9. M/s. Ravindra Enterprises,Opposite Petrol Pump ,Main Bazar Ner Chowk Mandi
10. M/s. Kumar Electric Co., Rajput Sabha Bhawan, Old Bus Stand, Distt Kangra,1716001 (H.P)

The Executive engineer (Elect) BSNL, Electrical, Division, 1st Floor Block No.35 Kasumpati Shimla-171009 invites the sealed quotation for the work name mentioned above. The quotations must reached on **11-04-2016** up 15.00 Hrs.at this office & will be opened on the same day at 15.30 Hrs. The nature of job and quantum of work has been explained in the schedule given below.

Name of work:- Replacement of Suction/ Discharge line of Submersible Pump in Adminstrative Building Hamirpur

S.No.	Description of item	Qty		Rate	Unit	Amount
1	Exhuming of existing the Submersible 3 HP Pump from bore of 100 Mtr app & lowering the same after in existing bore i/c making suitable arrangement for exhuming & lowering of pump-testing etc as required	1	Job		Job	
2	Replacement of 32mm GI pipe with 32mm HDPE pipe of total length 90 mtrs i/c testing for leakage etc as required	90	Job		Job	
	Note :- Dismantled old pipe GI will be proprty of Contractor hence rate should be quoted accordingly					
					Total	

Note:-

- 1 The work shall be done as per the specification of department.
2. The work shall be supervised by the qualified Engineer-in-charge or his duly authorized representative at the site of work.
3. The layout of the work will be given by the Engineer-in-charge or his duly authorized representative at the site of work.
4. Any damage done to the building by the contractor during the execution of work shall be made good by the contractor at his risk and cost, if the damage are not made good by the contractor in reasonable time determine by the Engineer-in-charge the same will be got done at his cost departmentally after serving notice to him.
5. No extra payment will be made for any kind of transportation.
- 6 The rates quoted should be inclusive of all taxes & duties i/c service tax . Nothing extra will be paid on this account
- 7.. Time allowed for completion of work shall be **7 Days** from the date of actual handing over

Executive Engineer (Elect)pl