

O/o Chief Engineer (Electrical)
BSNL, Electrical Zone
Third Floor, Block no. 5, Sector 6, Phase-III,
New Shimla-171009
Ph. 0177-2673701,2673211(Fax)



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No:21(02)/CE/E/BSNL/EZ/SML/2017-18/537

Dated 30.12.2017.

To
The EE(E) ✓
BSNL ED, CTTC Complex,
Sundernagar.

30/12/17

Corr - CE/E/SML/537
30/12/17

Subject : Rate Contract for SITC of 10nos. 10 KVA (at NTP) RTU Type Diesel E/A sets
with Sound Proof Enclosure for TE Buildings under BSNL Electrical Zone Shimla (HP).

Reference : DNIT issued vide this office letter no. 21(02)/CE/E/BSNL/EZ/SML/
2017-18/522 dated 20.12.2017.

Please refer to above. Following modification/correction in the above DNIT are
hereby authorized.

The condition mentioned (anywhere in the DNIT) as

"AIR COOLED TURBO CHARGED ENGINE"

May be read as

"AIR COOLED NATURAL ASPIRATED ENGINE"

All other terms & conditions of the DNIT will remain the same.

SDE(EP)
Pl upload as
Corrigendum to
NTP-25/EE/E/.../2017-18
dt:- 27/12/2017

SDE(EP) 30/12/2017