

BHARAT SANCHAR NIGAM LIMITED**भारत संचार निगम लिमिटेड**

(A Govt. of India Enterprise)

(भारत सरकार का उपक्रम)

O/o Sub Divisional Engineer (E),BSNL Electrical Sub Division, 1st Floor Block No. 35 Kasumpati Shimla-171009

कार्यालय उप मंडल अभियंता (विद्युत) भारत संचार निगम लिमिटेड ब्लॉक न. ३५ शिमला

No:-314SDE/E/BSNL/ESD./SML/18-19/90

Dated:- 08.10.2018

Notice Inviting Quotation

The Sub Divisional Engineer (Elect) BSNL, Electrical Sub Division, 1st Floor Block No.35 Kasumpati Shimla-171009 invites the sealed quotation for the work name mentioned below. The quotations must reached on **12-10-2018** up 15.00 Hrs.at this office & will be opened on the same day at 15.30 Hrs. The nature of job and quantum of work has been explained in the schedule given below.

The quotations can be downloaded from www.hp.bsnl.co.in**Name of work:- SITC of 15 KVA UPS at CTO, Shimla.(SH: Cable & Misc Items)**

S.No	Description of items	Qty		Rate	Unit	Amount
1	Supplying and laying following sizes of PVC insulated copper conductor armoured cable in the existing surface/cable chamber etc as required.					
(a)	4 x 4 sq. mm	85	Mtrs		Mtr	
(b)	4 x 6 sq. mm	10	Mtrs		Mtr	
2	Supplying and drawing following sizes of PVC insulated multi strand copper conductor single core cable in the surface/ etc as required.					
(a)	16 sq. mm	20	Mtrs		Mtr	
3	Supplying and fixing following way, horizontal type three pole and neutral, sheet steel, MCB distribution board, 415 volts, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)					
(a)	4 way (4 + 12), Double door	1	No		Each	
(b)	6 way (4 + 18), Double door	2	Nos		Each	
4	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.					
(a)	Single pole	12	No		Each	
(b)	Triple pole and neutral	4	Nos		Each	
(c)	Double pole	3	Nos		Each	
5	Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.					
(a)	4 x 4 sq. mm	4	Sets		Each	
(b)	4 x 6 sq. mm	4	Sets		Each	
Total -						

Note:-

- The work shall be done as per the specification of department.
- The work shall be supervised by the qualified Engineer-in-charge or his duly authorized representative at the site of work.
- The layout of the work will be given by the Engineer-in-charge or his duly authorized representative at the site of work.
- Any damage done to the building by the contractor during the execution of work shall be made good by the contractor at his risk and cost, if the damage are not made good by the contractor in reasonable time determine by the Engineer-in-charge the same will be got done at his cost departmentally after serving notice to him.
- No extra payment will be made for any kind of transportation.
- The rates quoted should be inclusive of all taxes & duties but excluding GST which will be paid extra**
- Time allowed for completion of work shall be **7 Days** from the date of award

--Sd----

Sub Divisional Engineer (Elect)
BSNL Electrical Division
Shimla

Contractor Signature with Seal

NIO:

Copy to :- All Enlisted Contractor & BSNL HP Web Site www.hp.bsnl.co.in
EE(E),BSNL,EZ,Shimla for information please

SDE/E/BSNL/ESD/SML/2018-19 dt 06.10.2018